



Wayne-Westland Community Schools
Drinking Water Analysis
Project Number: AE160005

Schweitzer Elementary School

Date of Sampling: November 16, 2016

Sampler: Lauren Koloski

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
SC - 01	Room 13	B	6:08 AM	15	ND ³	N	First Draw
SC - 02	Room 15	B	6:11 AM	15	ND	N	First Draw
SC - 03	Room 17	B	6:14 AM	15	3	N	First Draw
SC - 04	Room 19	B	6:17 AM	15	2	N	First Draw
SC - 05	Room 21	B	6:19 AM	15	3	N	First Draw
SC - 06	Room 22	B	6:21 AM	15	1	N	First Draw
SC - 07	Room 20	B	6:24 AM	15	ND	N	First Draw
SC - 08	Room 16	B	6:27 AM	15	ND	N	First Draw
SC - 09	Room 8	B	6:31 AM	15	ND	N	First Draw
SC - 10	Room 7	B	6:34 AM	15	ND	N	First Draw
SC - 11	Room 5	B	6:38 AM	15	1	N	First Draw
SC - 12	Outside Teachers Lounge, Right	B	6:40 AM	15	3	N	First Draw
SC - 13	Room 4	B	6:44 AM	15	ND	N	First Draw
SC - 14	Right of Kindergarten Room	B	6:47 AM	15	2	N	First Draw
SC - 15	Room 24	B	6:53 AM	15	ND	N	First Draw

1) Type: B = Bulletin, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, AS = Assembly Sink, SS = Sink Used for Drinking
2) <http://www.epa.gov/your-drinking-water/2015-regulated-drinking-water-contaminants>
3) ND = Non-Detect at Report Detection Limit of 1 ug/L