



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE170005

Stottlemeyer Early Childhood Center

Date of Sampling: January 19, 2017

Sampler: Lauren Koloski

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
ST-01	Room 130 bubbler	B	6:06 AM	15	5	N/A	First Draw
ST-02	Room 126 bubbler	B	6:12 AM	15	2	N/A	First Draw
ST-03	Room 122 bubbler	B	6:16 AM	15	3	N/A	First Draw
ST-04	Bubbler in hallway outside Room 116	B	6:22 AM	15	4	N/A	First Draw
ST-05	Room 112 bubbler	B	6:29 AM	15	10	N/A	First Draw
ST-06	Room 108 bubbler	B	6:31 AM	15	8	N/A	First Draw
ST-07	Room 104 bubbler	B	6:36 AM	15	ND	N/A	First Draw
ST-08	Room 103 bubbler	B	6:39 AM	15	13	N/A	First Draw
ST-09	Room 100 bubbler	B	6:41 AM	15	11	N/A	First Draw
ST-10	Room 101 bubbler	B	6:44 AM	15	10	N/A	First Draw
ST-11	Room 135 bubbler	B	6:51 AM	15	6	N/A	First Draw
ST-12	Left bubbler in hallway outside Main Office	B	6:48 AM	15	3	N/A	First Draw
ST-13	Teachers' Lounge sink	S	6:53 AM	15	5	Y	First Draw
ST-14	Room 134 bubbler	B	6:56 AM	15	5	N/A	First Draw
ST-15	Room 128 bubbler	B	6:59 AM	15	8	N/A	First Draw

1) Type: B = Bubbler; WC = Water Cooler; CF = Classroom Faucet; KS = Kitchen Sink; NS = Nurse Sink; S = Sink, used for Drinking
 2) <http://www.epa.gov/dw/dwdrinkingwater/contaminants/lead-drinking-water-contaminants>
 3) ND = Non-Detect or Below Detection Limit of 1 ug/L