



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE170005

Walker Winter Elementary School							
Date of Sampling: January 20, 2017							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
WW-01	Room 3	B	6:26 AM	15	ND	N/A	First Draw
WW-02	Room 7	B	6:29 AM	15	2	N/A	First Draw
WW-03	Right bubbler in hallway outside Media Center	B	6:35 AM	15	ND	N/A	First Draw
WW-04	Left bubbler in hallway outside Media Center	B	6:35 AM	15	1	N/A	First Draw
WW-05	Bubbler in Gym	B	6:38 AM	15	2	N/A	First Draw
WW-06	Right cooler in hallway outside Room 8	WC	6:41 AM	15	ND	N/A	First Draw
WW-07	Left cooler in hallway outside Room 8	WC	6:41 AM	15	ND	N/A	First Draw
WW-08	Room 8	B	6:45 AM	15	ND	N/A	First Draw
WW-09	Right bubbler in hallway next to Room 19	B	6:50 AM	15	ND	N/A	First Draw
WW-10	Left bubbler in hallway next to Room 19	B	6:50 AM	15	ND	N/A	First Draw
WW-11	Room 16	B	6:53 AM	15	ND	N/A	First Draw
WW-12	Room 21	B	6:55 AM	15	ND	N/A	First Draw
WW-13	Room 20	B	6:56 AM	15	ND	N/A	First Draw
WW-14	Room 23	B	7:00 AM	15	ND	N/A	First Draw
WW-15	Room 27	B	7:04 AM	15	ND	N/A	First Draw

¹ Type: B #Bubbler, WC # Water Cooler, CF # Classroom, Recler, KS # Kitchen Sink, ND #Nurse Sink, SA #Sink used for Drinking
² <http://www.epa.gov/epaonline/drinkingwater/tables/reguledcont.html>
³ ND # Non-Detect # Report Detection Limit of 1 ug/L